



ORDER #: _____ DATE: _____

PROJECT: _____

LOCATION: _____

CUSTOMER: _____

APPROVED: _____ DATE: _____

MODEL	O.D. OF CURB	QUANTITY
5555	51" X 51"	
5566	51" X 63"	
5578	51" X 75"	
5596	51" X 93"	
55102	51" X 99"	
6666	63" X 63"	
6678	63" X 75"	
6696	63" X 93"	
66102	63" X 99"	

FINISH: MILL (STANDARD)

OTHER _____

ACRYLIC GLAZING:

OUTER	INNER
CLEAR	CLEAR
#2412 BRONZE	#2447 WHITE

CAUTION: WHEN INSTALLING THIS PRODUCT THE AREA BELOW THE UNIT MUST BE CLEAR OF OBSTRUCTIONS WHICH COULD IMPEDE THE RELEASE OF THE DOMES.



AUTOMATICALLY OPERATED ROOF VENT
4LM7 ROOF CLASS 90
UL LISTED UNITS ARE DESIGNED TO DROP
OUT IN LESS THAN 5 MINUTES AT 500°F
WHEN SUBJECTED TO THE STANDARD UL
793 FIRE EXPOSURE TEST.

CSOS CURB MOUNT SHRINK-OUT SMOKE VENT

DATE: 05/2019	DRAWING NO.: CSOS	REV 0	SHEET 1 OF 1
------------------	----------------------	----------	-----------------